

OBJECTIVE:

This course is deals with Economic operation of power system, hydrothermal scheduling and modeling of turbines, generators and automatic controllers. It emphasizes on single area and two area load frequency control and reactive power control.

GROUP-I (SHORT ANSWER TYPE QUESTIONS)

S.No	QUESTION	BLOOMS TAXONOMY LEVEL	COURSE OUTCOME
UNIT-I			
Economic Operation of Power Systems-1			
1	Define in detail the following: i. Control variables ii. Disturbance variables iii. State variables.	Remember	1
2	Draw incremental fuel cost curve.	Understand	1
3	Explain the significance of equality and inequality constraints in the economic al- location of generation among different plants in a system.	Understand	1
4	What is Production cost of power generated and incremental fuel rate?	Remember	1
5	Write the expression for hourly loss of economy resulting from error in Incremental cost representation	Apply	1
6	Discuss in detail about incremental heat rate curve and cost curve	Understand	1
7	Write the expression for hourly loss of economy resulting from error in incremental cost representation.	Remember	1
8	What is load factor and loss factor and state the criterion for economic operation of power system?	Understand	

9	Explain the following terms with reference to power plants: Heat input - power output curve, Heat rate input, Incremental input, Generation cost and Production cost.	Remember	1
10	What are the methods of scheduling of generation of steam plants? Explain their merits and demerits?	Understand	1
<p>UNIT-II</p> <p>Economic Operation of Power Systems-2</p>			
1	Draw flow chart for economic scheduling without considering line losses.	Understand	2
2	Explain optimal load flow solution without inequality constraints.	Remember	2
3	Derive transmission loss formula in terms of B- coefficients.	Apply	2
4	Draw the flow chart for economic scheduling neglecting the transmission loss.	Remember	2
5	Explain about economic load dispatch neglecting the losses.	Understand	2
6	What is the role of spinning reserve in unit commitment?	Understand	2
7	With the help of a flow chart, explain the dynamic programming method in unit commitment	Remember	2
8	What is a "Load Curve"?	Remember	2
9	Write the equality and inequality constraints considered in the economic dispatch problem.	Understand	2
10	What is the function of load dispatch centre?	Understand	2
<p>UNIT-III</p> <p>Hydrothermal Scheduling</p>			
1	Discuss the combined hydro- electric and steam station operation.	Remember	2
2	Describe different methods for solving hydro thermal scheduling.	Understand	2
3	What are the requirements of control strategy in integral control? Explain the role played by the controller's gain setting in the frequency control.	Understand	2
4	Explain about Hydro thermal co-ordination with necessary equations.	Remember	2
5	Describe the objective function is minimize the cost of generation of hydro thermal scheduling	Understand	2
6	Explain problem formation and solution procedure of optimal scheduling for hydro thermal plants.	Understand	2
7	Briefly explain about the plant level and the system level controls.	Understand	2
8	Explain Constant Hydro Generation method	Remember	2
9	Explain Constant Thermal Generation method	Remember	2
10	Explain Maximum Hydro Efficiency method	Remember	2
<p>UNIT-IV</p> <p>Modeling of Turbines</p>			
1	Describe the mathematical model of Speed - Governing System.	Apply	3
2	Explain D.C excitation system and A.C excitation system.	Remember	3
3	Derive the model of a speed governing system and represent it by a block diagram.	Apply	3

4	Explain the objectives and functions of Automatic Generation Control (AGC) in a power system.	Understand	3
5	Explain how mathematical model of speed governing system is developed for Automatic Generation Control.	Understand	3
6	Distinguish between AVR and ALFC control loops of a generator.	Remember	3
7	What is “AGC”?	Remember	3
8	What decides the loading of generating stations?	Understand	3
9	Explain Selecting frequency control.	Remember	3
10	Explain TIE Line bias control.	Understand	3

UNIT-V

Single Area Load Frequency Control

1	Explain the necessity of keeping the frequency constant in a power system.	Understand	4
2	Explain what is meant by control area. Obtain the transfer function model and explain ALFC of a single area of an isolated power system	Understand	4
3	Write notes on: i) Control area concept. ii) Area control error.	Remember	4
4	Explain Isolated Power system.	Remember	4
5	Explain the steady state analysis in controlled case.	Remember	4
6	Explain the steady state analysis in un-controlled case.	Understand	4
7	Explain what are the methods to keep the frequency constant?	Remember	4
8	Explain the dynamic response.	Understand	4
9	A 100 MVA synchronous generator operates on full load at a frequency of 50 Hz. The load is suddenly reduced to 50 MW. Due to time lag governor system, the steam valve begins to close after 0.4 sec. Determine the change in frequency that occurs in this time. Given the initial constant $H=5 \text{ KW-sec/KVA}$.	Apply	4
10	A control area has total rated capacity of 10000MW. The regulation R for all the units in the area is 2 HZ/P.U, A 1% change in frequency causes a 1% change in load. If the system operates at half the rated capacity and increases by 2% i) Find the static frequency drop ii) If the speed governor loop were open, what will be the frequency	Apply	4

UNIT-VI

Two-Area Load Frequency Control

1	Obtain the dynamic response of load frequency controller with integral control action in two area load frequency control system.	Understand	4
2	Explain the state variable model of two area load frequency controller with integral	Remember	4
3	What are the different states of power system? Explain	Remember	4

4	Explain with relevant diagram, tie line bias control of a two area system.	Understand	4
5	Explain two area control system.	Remember	4
6	Explain the Pool operation of station.	Remember	4
7	Explain the expected load changes.	Remember	4
8	Explain the unexpected generator outages.	Remember	4
9	Draw and explain composite block diagram of two area system.	Understand	4
10	Derive the expression for response of two area system.	Apply	4

UNIT-VII

Load Frequency Controllers

1	Explain the state variable model of single area load frequency controller with integral action.	Understand	4
2	Discuss the importance of combined load frequency control and economic dispatch control with a neat block diagram.	Understand	4
3	What are the requirements of control strategy in integral control? Explain the role played by the controller's gain setting in the frequency control.	Remember	4
4	Obtain an expression for steady state response of a load frequency controller with integral control. How it is different from without integral control.	Apply	4
5	Discuss the merits of proportional plus integral load frequency control of a system with a neat block diagram.	Understand	4
6	What are the various methods of voltage control in transmission system?	Remember	4
7	Explain the need for voltage and frequency regulation in power system.	Remember	4
8	What is the function of Load Frequency Control?	Understand	4
9	What is the purpose of primary ALFC?	Understand	4
10	List out the various needs for frequency regulation in power system.	Remember	4

UNIT-VIII

Reactive Power control

1	Explain about the losses that occur due to VAR own in power systems.	Remember	5
2	Explain how the generators act as VAR sources in a power network.	Understand	5
3	Explain how the voltage control is achieved by injection of power at nodes.	Understand	5
4	What is voltage instability? Explain the phenomenon of voltage collapse with relevant PV and QV diagram	Understand	5
5	Explain different sources of reactive power generation and absorbers of reactive power in a power system.	Remember	5
6	What is meant by sub synchronous resonance? Briefly explain	Remember	5
7	Briefly explain voltage instability and voltage collapse	Understand	5
8	What is series compensation? Explain the advantages of series compensation.	Understand	5
9	Explain about the generation and absorption of reactive power in an electrical power system.	Remember	5
10	Derive the equations to get the relation between voltage between voltage, power and reactive power at a node.	Apply	5

UNIT-I			
Economic Operation of Power Systems-1			
S.No	QUESTION	BLOOMS TAXONOMY LEVEL	COURSE OUTCOME
1	Explain in detail the terms production costs, total efficiency, incremental efficiency and incremental rates with respect to thermal power plant.	Understand	1
2	Explain the diagram the physical interpretation of coordination equation.	Remember	1
3	Give various uses of general loss formula and state the assumptions made for calculating B_{mn} coefficients.	Apply	1
4	Give step by step procedure for computing economic allocation of generation in a thermal station.	Remember	1
5	Write assumptions involved in deriving a loss formula coefficients.	Apply	1
6	The fuel cost for a two unit steam power plant are given by $C_1 = 0.1 P_1^2 + 25 P_1 + 1.6$ Rupees/hour $C_2 = 0.1 P_2^2 + 32 P_2 + 2.1$ Rupees/hour Where p's are in megawatt. If there is an error of 1% in the representation of the input data, and the loss in operating economy for a load of 250 MW.	Analyze	1
7	A power System consists of two, 125 MW units whose input cost data are represented by the equations : $C_1 = 0.04 P_1^2 + 22 P_1 + 800$ Rupees/hour $C_2 = 0.045 P_2^2 + 15 P_2 + 1000$ Rupees/hour If the total received power $P_R = 200$ MW. Determine the load sharing between units for most economic operation.	Analyze	1
8	100 MW, 150 MW and 280 MW are the ratings of three units located in a thermal power station. Their respective incremental costs are given by the following equations: $dc_1/dp_1 = Rs(0.15p_1 + 12);$ $dc_3/dp_3 = Rs(0.21p_3 + 13)$ $dc_2/dp_2 = Rs(0.05p_2 + 14)$ Where P_1, P_2 and P_3 are the loads in MW. Determine the economical load allocation between the three units, when the total load on the station is 300 MW.	Apply	1
	150 MW, 220 MW and 220 MW are the ratings of three units located		

9	<p>in a thermal power station. Their respective incremental costs are given by the following equations:</p> $dc1/dp1 = Rs(0.11p1 + 12);$ $dc3/dp3 = Rs(0.1p3 + 13)$ $dc2/dp2 = Rs(0.095p2 + 14)$ <p>Where P1, P2 and P3 are the loads in MW. Determine the economical load allocation between the three units, when the total load on the station is</p> <p>(a) 350 MW (b) 500 MW.</p>	Analyze	1
10	<p>What is mean by unit commitment problem? Discuss a method for solving the same.</p>	Remember	
<p>UNIT-II Economic Operation of Power Systems-2</p>			
1	<p>Discuss the dynamic programming method to solve unit commitment problem in power system.</p>	Understand	2
2	<p>Develop a load flow equation suitable for solutions by Gauss-seidal method using nodal admittance approach.</p>	Remember	2
3	<p>The incremental fuel cost for two plants are</p> $dC1 /d PG1 = 0.075 PG1 + 18 \text{ Rs./MWh}$ $dC2 / d PG2 = 0.08 PG2 + 16 \text{ Rs./MWh}$ <p>The loss coefficients are given as</p> $B11=0.0015 /MW, B12 = - 0.0004/MW \text{ and } B22 = 0.0032/MW \text{ for } R = 25 \text{ Rs./MWh.}$ <p>Find the real power generations, total load demand and the transmission power loss.</p>	Apply	2
4	<p>Two power stations A and B operate in parallel. They are interconnected by a short transmission line. The station capacities are 100 MW and 200 MW respectively. The generators A and B have speed regulations of 3 % and 2 % respectively. Calculate the output of each station and load on the interconnector, if,</p> <p>(a) The load on each station is 125 MW (b) The load on respective bus bars is 60 MW and 190 MW (c) The load is 150 MW at station A bus bar only.</p>	Analyze	2

5	Give algorithm for economic allocation of generation among generators of thermal system taking into account transmission losses. Give steps for implementing this algorithm and also derive necessary equations.	Understand	2
6	Write a short notes on: a) Inequality constraints. b) Penalty function.	Remember	2
7	A power system consists of two 100MW units whose input cost data are represented by equations below $C_1 = 0.04 P_1^2 + 22P_1 + 800$ Rs/hr $C_2 = 0.045 P_2^2 + 15P_2 + 1000$ Rs/hr If total received power $P_R = 150$ MW. Determine (a) The load sharing between units for most economic operation (b) The corresponding costs of operations	Apply	2
8	Give the computational procedure for optimal power flow without inequality constraints.	Remember	2
9	Discuss optimal power flow problems without and with inequality constraints. How are these problems solved.	Understand	2
10	Using dynamic programming method, how do you find the most economical combination of the units to meet a particular load demand?	Apply	2

UNIT-III
Hydrothermal Scheduling

1	In a two plant operation system, the hydro plant is operation for 10 hrs, during each day and the steam plant is to operate all over the day. The characteristics of the steam and hydro plants are $CT = 0.04 P_{GT}^2 + 30 P_{GT} + 10$ Rs/hr $WH = 0.12 P_{GH}^2 + 30 P_{GH}$ m ³ / sec When both plants are running, the power own from steam plant to load is 150 MW and the total quantity of water is used for the hydro plant operation during 10 hrs is 150x10 ⁶ m ³ . Determine the generation of hydro plant and cost of water used. Neglect the transmission losses.	Analyze	2
2	In a two plant operation system, the Hydro plant is operate for 12 hrs. During each day and the hydro plant is operate all over the day. The characteristics of the steam and hydro plants are $CT = 0.3 P_{GT}^2 + 20 P_{GT} + 5$ Rs/hr $WH = 0.4 P_{GH}^2 + 20 P_{GH}$ m ³ / sec When both plants are running, the power own from steam plant to load is 300	Analyze	2

	<p>MW and the total quantity of water used for the hydro plant operation during 12 hrs is 180×10^6 m³. Determine the generation of hydro plant and cost of water used.</p>								
3	Briefly explain control area concept and control area error.	Remember	2						
4	Explain proportional plus integral control for load frequency control for a single area system.	Understand	2						
5	Two generators rated 300 MW and 400 MW are operating in parallel. The droop characteristics of their governors are 4% and 6% respectively from no load to full load. The speed changers of the governors are set so that a load of 400 MW is shared among the generators at 50 HZ in the ratio of their ratings. What are the no load frequencies of the generators.	Apply	2						
6	Explain load frequency control problem.	Remember	2						
7	<p>A two plant hydro-thermal system with negligible losses has the following characteristics. Fuel cost as a function of active power generated at the thermal plant is $F = (2p_1 + 0.01p_1^2)$ RS/hr. The optimal water conversion coefficient is found to be 12.01RS/MCF. The load on the system is</p> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse;"> <tr> <td style="padding: 5px;">Duration (b)</td> <td style="padding: 5px; text-align: center;">9</td> <td style="padding: 5px; text-align: center;">15</td> </tr> <tr> <td style="padding: 5px;">DD (MW)</td> <td style="padding: 5px; text-align: center;">700</td> <td style="padding: 5px; text-align: center;">350</td> </tr> </table> <p>Compute the optimal active thermal and hydro power generations (in MW) in each of the subintervals and the allowable volume of water at the hydro plant.</p>	Duration (b)	9	15	DD (MW)	700	350	Analyze	2
Duration (b)	9	15							
DD (MW)	700	350							
8	A 3-phase single circuit, 220kV, line runs at no load. Voltage at the receiving end of the line is 205kV. Find the sending end voltage, if the line has resistance 21.7ohms, reactance of 85.2ohms and the total susceptance of 5.32×10^{-4} mho. The transmission line is to be represented by Pie-model.	Apply	2						
9	Explain the problem of scheduling hydro thermal power plants. What are the constraints in the problem?	Understand	2						
10	Explain clearly the mathematical formulation of optimal scheduling of hydrothermal system with a typical example.	Understand	2						
<p>UNIT-IV</p> <p>Modeling of Turbines</p>									
1	Explain the hydro thermal co- ordination in brief.	Understand	3						
2	Explain the co- ordination for Run-Off river and steam plan	Remember	3						
3	<p>Draw the block diagram of a power system showing the governor, turbine and Synchronous generator, indicating their transfer functions. For a step disturbance of PD, obtain the response of increment in frequency", making suitable assumptions.</p> <p>(a) Without proportional plus integral controller and</p>	Understand	3						

	(b) With proportional plus integral control.		
4	Derive general mathematical formulation of long term hydro thermal scheduling.	Apply	3
5	Derive general mathematical formulation of Short term hydro thermal scheduling	Apply	3
6	Explain the problem discretization principle.	Remember	3
7	Solution of short term hydro thermal scheduling problems by Kirchamayers method.	Understand	3
8	Advantages of operation of hydro thermal combination.	Remember	3
9	Give a typical block diagram for a two area system interconnected by a tie line and explain each block. Also deduce relations to determine the frequency of oscillations of the tie line power and static frequency drop. List out assumptions made.	Understand	3
10	Write short notes on area control error.	Remember	3

UNIT-V

Single Area Load Frequency Control

1	Explain the governor characteristics of a single generator.	Understand	4
2	What is the nature of the steady state response of the uncontrolled LFC of a single area?	Remember	4
3	State briefly how the time response of the frequency error depends upon the gain setting of the integral control.	Remember	4
4	What are the basic requirements of a closed loop control system employed for obtaining the frequency constant?	Understand	4
5	What is the nature of the generator load frequency characteristic?	Remember	4
6	With a neat block diagram explain the load frequency control for a single area system.	Understand	4
7	Draw and explain complete block diagram representation of single area having a turbo-generator supplying an isolated load for load frequency problem. Discuss the response of the system for a sudden change in load demand.	Remember	4
8	Give a brief account on tie line bias bar control.	Remember	4
9	Explain speed governing mechanism in two generators or machines system.	Understand	4
10	Develop and explain the load frequency control of a single area system of an uncontrolled case drive the transfer function of each block.	Understand	4

Two-Area Load Frequency Control

1	<p>Two areas of a power system network are interconnected by a tie-line, whose capacity is 250MW, operating at a power angle of 45°. If each area has a capacity of 2000 MW and the equal speed regulation of 3 Hz/Pu MW, determine the frequency of oscillation of the power for step change in load. Assume that both areas have the same inertia constants of $H = 4$ sec. If a step load change of 100MW occurs in one of the areas determine the change in tie-line power.</p>	Apply	4
2	<p>Two power systems, A and B, having capacities of 3000 and 3000 MW, respectively, are interconnected through a tie-line and both operate with frequency-bias-tie-line control. The frequency bias for each area is 1 % of the system capacity per 0.1 Hz frequency deviation. If the tie-line interchange for A is set at 100 MW and for B is set (incorrectly) at 200 MW, calculate the steady state change in frequency.</p>	Apply	4
3	<p>Two control areas have the following characteristics:</p> <p>Area-1: Speed regulation = 0.02 pu ,Damping coefficient = 0.8 pu ,Rated MVA = 1500</p> <p>Area-2: Speed regulation = 0.025 pu, Damping co-efficient = 0.9 pu, Rated MVA = 500</p> <p>Determine the steady state frequency change and the changed frequency following a load change of 120MW occurs in area-1. Also find the tie-line power flow change.</p>	Apply	4
4	<p>The two area system has the following data:</p> <p>Capacity of area 1, $P_{r1} = 1000$ MW,</p> <p>Capacity of area 2, $P_{r2} = 2000$ MW,</p> <p>Nominal load of area 1, $P_{D1} = 500$ MW</p> <p>Nominal load of area 2, $P_{D2} = 1500$ MW</p> <p>Speed regulation of area 1 = 4%</p> <p>Speed regulation of area 2 = 3%</p> <p>Find the new steady state frequency and change in the line ow for a load change of area 2 by 125 MW. For both the areas each percent change in frequency causes 1 percent change in load. Find also the amount of additional</p>	Analyze	4

	frequency drop if the interconnection is lost due to certain reasons.		
5	<p>Explain the state variable model of two area load frequency controller with integral action. Two control areas connected by a tie line have the following characteristics.</p> <p>Area 1 Area 2</p> <p>$R=0.01$ pu $R=0.02$ pu</p> <p>$D=0.8$ pu $D=1.0$ pu</p> <p>Base MVA=2000 Base MVA=500</p> <p>A load change of 100 MW (0.2 pu) occurs in area 1. What is the new steady state frequency and what is the change in the tie own? Assume both areas were at nominal frequency (60 Hz) to begin.</p>	Apply	4
6	Two generators rated 250 MW and 500 MW are operating in parallel. The droop characteristics are 4% and 6% respectively. Assuming that the generators are operating at 50 HZ at no load, how a load of 750 MW would be shared. What is the system frequency? Assume free governor action	Analyze	4
7	Draw the block diagram of load frequency control of 2- area control systems with gain blocks.	Understand	4
8	What is area control error? What are the control strategies?	Remember	4
9	Explain proportional plus integral control for load frequency control for a single area system.	Remember	4
10	Give a typical block diagram for a two area system interconnected by a tie line and explain each block. Also deduce relations to determine the frequency of oscillations of tie line power and static frequency drop. List out assumptions made.	Understand	4
UNIT-VII Load Frequency Controllers			
1	What is load frequency control problem? Why is it essential to maintain constant frequency in an inter connected power system?	Remember	4
2	Explain the power frequency characteristics of an interconnected power system.	Remember	4
3	Explain load frequency control problem, and derive an expression for steady state change of frequency and tie-line power transfer of a two area power system.	Understand	4
4	With a first order approximation explain the dynamic response of an isolated area for load frequency control.	Understand	4
5	Derive the transfer function of an uncontrolled load frequency control of a single area system and derive the expression for static error following a step load change.	Apply	4

6	Explain the proportional plus integral control of single area.	Remember	4
7	Derive the expression for analysis of integral control or steady state response.	Apply	4
8	Explain load frequency control and economic dispatch control.	Understand	4
9	What are the requirements of control strategy?	Remember	4
10	Find the expression for dynamic response of change in frequency for a step change in load for a single area control system with integral control action. Assume that $T_g=0$; $T_t=0$ and damping constant.	Apply	4

UNIT-VIII
Reactive Power control

1	Explain about the losses occurred due to VAR flow in power system.	Remember	5
2	Explain how the generators are acted as VAR sources in a power network.	Remember	5
3	Write short notes on compensated and uncompensated transmission lines.	Remember	5
4	Explain briefly about the shunt and series compensation.	Understand	5
5	What is load compensation? Discuss its objectives in power systems	Understand	5
6	The load at receiving end of a three-phase, over head line is 25.5 MW, power factor 0.8 lagging, at a line voltage of 33 kV. A synchronous compensator is situated at receiving end and the voltage at both the ends of the line is maintained at 33 kV. Calculate the MVAR of the compensator. The line has a resistance of 4.5 ohms per phase and inductive reactance (line to neutral) of 20 ohms per phase.	Analyze	5
7	What is load compensation? Discuss its objectives in power system.	Remember	5
8	A long transmission line has the constants $A=0.971\angle 2^\circ$, $B=\angle 75^\circ$, find the additional reactive power requirement at the receiving end to meet a load of 63 MW at 0.8 p.f. lagging, when both the sending end and receiving end voltages are to be maintained at 132 KV.	Apply	5
9	Explain the reason for variations of voltages in power systems and explain any one method to improve voltage profile.	Understand	5
10	Explain clearly what you mean by compensation of line and discuss briefly different methods of compensation.	Understand	5

GROUP-III (ANALYTICAL QUESTIONS)

S.No	QUESTIONS	BLOOMS TAXONOMY LEVEL	PROGRA MOUTCO ME
UNIT-I			
Economic Operation of Power Systems-1			
1	<p>Incremental fuel cost is Rs/MWhr for a plant of a two units. $dc1/dpg1=0.25 pg1+40$; $dc2/dpg2=0.3 pg2+30$</p> <p>Assume that both the units are operating at all times and total load varies from 40 MW to 250 MW. How will the load be shared for a load of 200 MW? What is the corresponding value of plant incremental cost? Also determine the saving in the fuel cost in Rs/hr for one optimum scheduling of 250 MW as compared to equal distribution of same load between two plants.</p>	Apply	1
2	<p>The incremental fuel cost in rupees per MWhr for a plant consisting of two units are $dC1/dPG1 =0.20 PG1+40.0$; $dC2/dPG2 =0.25 PG2+30.0$ Assume that both units are operating at all times and total load varies from 40 MW to 250 MW and maximum and minimum loads on each unit are to be 125 MW and 20MW respectively .How will the load be shared between the units as the system varies over full range? What are the plant incremental costs?</p>	Analyze	1
3	<p>The fuel inputs per hour of plants 1 and 2 are given as $F1 =0.2 P1$ $2+40 P1+120$ Rs per hr. $F2 =0.25 P_2^2+30 P2+150$ Rs per hr.</p> <p>Determine the economic operating schedule and the corresponding cost of generation if the maximum and minimum loading on each unit is 100 MW and 25 MW,the demand is 180 MW and transmission losses are neglected. If the load is equally shared by both the units, determine the saving obtained by loading the units as per the incremental production cost.</p>	Apply	1
4	<p>Let us consider a generating station that contains a total number of three generating units. The fuel costs of these units are given by</p> $f_1 = \frac{0.8}{2} P_1^2 + 10P_1 + 25 \quad \text{Rs./h}$ $f_2 = \frac{0.7}{2} P_2^2 + 5P_2 + 20 \quad \text{Rs./h}$ $f_3 = \frac{0.95}{2} P_3^2 + 15P_3 + 35 \quad \text{Rs./h}$	Analyze	1

		<p>The generation limits of the units are $30 \text{ MW} \leq P_1 \leq 500 \text{ MW}$</p> <p>$30 \text{ MW} \leq P_2 \leq 500 \text{ MW}$</p> <p>$30 \text{ MW} \leq P_3 \leq 250 \text{ MW}$</p> <p>The total load that these units supply varies between 90 MW and 1250 MW. Assuming that all the three units are operational all the time, we have to compute the economic operating settings as the load changes.</p>		
5	6	<p>Consider two generating plant with same fuel cost and generation limits. These are given by</p> $f_i = \frac{0.8}{2} P_i^2 + 10P_i + 25 \text{ Rs./h} \quad i = 1,2$ <p>$100 \text{ MW} \leq P_i \leq 500 \text{ MW}, \quad i = 1,2$</p> <p>For a particular time of a year, the total load in a day varies as shown in Fig. 5.2. Also an additional cost of Rs. 5,000 is incurred by switching of a unit during the off peak hours and switching it back on during the during the peak hours. We have to determine whether it is economical to have both units operational all the time</p>	Analyze	1
6	7	<p>The fuel inserts per all of plants I and II are given as</p> <p>$F_1 = 0.1P_1^2 + 40 P_1 + 120 \text{ Rs/Hr}$</p> <p>$F_2 = 0.25P_2^2 + 30P_2 + 150 \text{ Rs/Hr}$. Determine the economic operating schedule and corresponding cost of generation if the max and min loading on each unit is 100 MW and 25 MW and the demand is 180 MW and transmission losses are neglected. If the load is equally shared by the both the units, determine the saving obtained by loading the units as per equal incremental products and cost.</p>	Apply	1
7	8	<p>A power system network with a thermal power plant is operating by four generating units. Determine the most economical unit to be committed to a load demand of 8 MW. Also prepare the UC table for the load. The min and max generating capacities and cost curve parameters of the units listed in a tabular form are given.</p>	Apply	1
8	9	<p>A power system network with a thermal power plant is operating by four generating units Determine the most economical unit to be committed to a load demand of 10 MW. Also prepare the UC table for the load changes in steps of 1 MW starting from the min and max generating capacities and cost curve parameters of the units listed in a tabular form are given.</p>	Analyze	1
9		<p>A power system network with a thermal power plant is operating by four generating units Determine the most economical unit to be committed to a load demand of 20 MW. Also prepare the UC table for the load changes in steps of 4 MW starting from the min and max generating capacities and cost curve parameters of the units listed in a tabular form are given.</p>	Analyze	1

10	<p>A power system network with a thermal power plant is operating by four generating units. Determine the most economical unit to be committed to a load demand of 30 MW. Also prepare the UC table for the load changes in steps of 8 MW starting from the min and max generating capacities and cost curve parameters of the units listed in a tabular form are given.</p>	Apply	1
<p>UNIT-II Economic Operation of Power Systems-2</p>			
1	<p>For the system shown in figure, with bus 1 as reference bus with a voltage of $1.0 \angle 0^\circ$ pu, find the loss formula co-efficient if the branch currents and impedances are: $I_a = 1.00 + j0.15$ p.u; $Z_a = 0.02 + j0.15$ p.u $I_c = 0.20 - j0.05$ pu; $Z_c = 0.02 + j0.25$ pu. If the base is 100 MVA, what will be the magnitudes of B – coefficients in reciprocal MW?</p> <div style="text-align: center; margin-top: 10px;"> </div>	Analyze	2
2	<p>(i) A generating station has a maximum demand of 50,000 kW. Calculate the cost per unit generated from the following data. Capital cost = Rs. 95 $\square \square 10^6$ Annual load factor = 40% Annual cost of fuel and oil = Rs. 9 $\square \square 10^6$ Taxes, wages and salaries etc = Rs. 7.5 $\square \square 10^6$ Interest and Depreciation = 12%.</p> <p>(ii) (1) Define ‘‘diversity factor’’. (2) Define ‘‘Plant use factor’’</p>	Analyze	2
3	<p>The fuel cost functions in Rs/hr for two thermal plants are given by $C_1 = 420 + 9.2P_1 + 0.004P_1^2$; $C_2 = 350 + 8.5P_2 + 0.0029P_2^2$ Where P_1, P_2 are in MW. Determine the optimal scheduling of generation if the load is 640.82 MW. Estimate value of $\lambda = 12$ Rs/MWhr. The transmission power loss is given by the expression $P_{L(p.u)} = 0.0346P_{1(p.u)}^2 + 0.00643P_{2(p.u)}^2$</p>	Apply	2
4	<p>The fuel cost functions in Rs/hr for two thermal plants are given by $C_1 = 420 + 9.2P_1 + 0.004P_1^2$, $100 < P_2 < 200$; $C_2 = 350 + 8.5P_2 + 0.0029P_2^2$, $150 < P_3 < 500$ Where P_1, P_2 are in MW. Determine the optimal scheduling of generation if the load is 640.82 MW. Estimate value of $\lambda = 12$ Rs/MWhr. The transmission power loss is given by the expression $P_{L(p.u)} = 0.0346P_{1(p.u)}^2 + 0.00643P_{2(p.u)}^2$</p>	Apply	2
5	<p>The IFC for two plants are $dC_1/dP_{G1} = 0.075 P_{G1} + 18$ Rs/hr ; $dC_2/dP_{G2} = 0.08P_{G2} + 16$ Rs/hr</p>		2

	The loss coefficients are given as $B_{11}=0.0015/\text{MW}$, $B_{12}= -0.00004/\text{MW}$, $B_{22} = 0.0032/\text{MW}$ for $\lambda=25 \text{ Rs/MWhr}$. Find the real power generations, total load demand, and the transmission power loss.	Analyze	
6	A system consists of two power plants connected by a transmission line. The total load located at a plant-2 is as shown in below. Data of evaluating loss coefficients consists of information that a power transfer of 100 MW from station-1 to station-2 results in a total loss of 8 MW. Find the required generation at each station and power received by the load when λ of the system is Rs. 100/MWhr. The IFCs of the two plants are given by $dC_1/dP_{G1}=0.12P_{G1}+65 \text{ Rs/MWhr}$; $dC_2/dP_{G2}=0.25P_{G2}+75 \text{ Rs/MWhr}$	Analyze	2
7	For above problem with 212.5 MW received by the load, find the savings in Rs/hr obtained by co-coordinating the transmission losses rather than neglecting in determining the load division between the plants	Analyze	2
8	Determine the incremental cost of received power and the penalty factor of the plant shown, if the incremental cost of production is $dC_1/dP_{G1}=0.1P_{G1}+3.0 \text{ Rs/MWhr}$.	Apply	2
9	Assume that the fuel input in Btu per hour for units 1 and 2 are given by $C_1=(8P_{G1}+0.024P_{G2}^2+80)10^6$; $C_2=6P_{G1}+0.04P_{G2}^2+120)10^6$ The maximum and min loads on the units are 100 and 10 MW, respectively. Determine the min cost of generation when the following load is supplied. The cost of fuel is Rs.2 per million Btu.	Apply	2
10	Two power plants are connected together by a transmission line and load at plant-2. When 100 MW is transmitted from plant-1, the transmission loss is 100 MW. The cost characteristics of two plants are $C_1=0.05P_{G1}^2+13P_{G1}$; $C_2=0.06P_{G2}^2+12P_{G2}$ Find the optimum generation for $\lambda=22, \lambda=25$ and $\lambda=30$.	Apply	2
UNIT-III Hydrothermal Scheduling			
1	In a two plant operation system, the hydro plant is operation for 10 hrs, during each day and the steam plant is to operate all over the day. The characteristics of the steam and hydro plants are $CT = 0.04 PGT^2 + 30 PGT + 10 \text{ Rs/hr}$ $WH = 0.12 PGH^2 + 30 PGH \text{ m}^3/\text{sec}$ When both plants are running, the power own from steam plant to load is 150 MW and the total quantity of water is used for the hydro plant operation during 10 hrs is $150 \times 10^6 \text{ m}^3$. Determine the generation of hydro plant and cost of water used. Neglect the transmission losses.	Apply	3
2	In a two plant operation system, the Hydro plant is operate for 12 hrs. During each day and the hydro plant is operate all over the day. The characteristics of the steam and hydro plants are	Apply	3

	$CT = 0.3 P_{GT}^2 + 20 P_{GT} - 5$ Rs/hr $WH = 0.4 P_{GH}^2 + 20 P_{GH}$ m ³ / sec								
	<p>When both plants are running, the power own from steam plant to load is 300 MW and the total quantity of water is used for the hydro plant operation during 12 hrs is 180×10^6 m³. Determine the generation of hydro plant and cost of water used.</p>								
3	<p>A two plant system having a steam plant near the load center and hydro plant at a remote location. The load is 500 MW for 16 hr a day and 350 MW for 8 hr a day.</p> <p>The characteristics of the units are $C_1 = 120 + 45 P_{GT} + 0.075 P_{GT}^2$; $w_2 = 0.6 P_{GH} + 0.002 P_{GH}^2$ m³/s. Loss coefficient $B_{22} = 0.001 MW^{-1}$. Find the generation schedule, daily water used by the hydro plant and daily operating cost of the thermal plant for $r_j = 85.5$ Rs/m³-hr</p>	Analyze	3						
4	<p>A two plant system having a steam plant near the load center and hydro plant at a remote location. The load is 400 MW for 14 hr a day and 200 MW for 10 hr a day.</p> <p>The characteristics of the units are $C_1 = 150 + 60 P_{GT} + 0.1 P_{GT}^2$ Rs/hr; $w_2 = 0.8 P_{GH} + 0.000333 P_{GH}^2$ m³/s. Loss coefficient $B_{22} = 0.001 MW^{-1}$. Find the generation schedule, daily water used by the hydro plant and daily operating cost of the thermal plant for $r_j = 77.5$ Rs/m³-hr</p>	Analyze	3						
5	<p>Two generators rated 300 MW and 400 MW are operating in parallel. The droop characteristics of their governors are 4% and 6% respectively from no load to full load. The speed changers of the governors are set so that a load of 400 MW is shared among the generators at 50 HZ in the ratio of their ratings. What are the no load frequencies of the generators.</p>	Apply	3						
6	<p>A two plant system having a steam plant near the load center and hydro plant at a remote location. The load is 600 MW for 12 hr a day and 450 MW for 5 hr a day.</p> <p>The characteristics of the units are $C_1 = 130 + 55 P_{GT} + 0.5 P_{GT}^2$; $w_2 = 0.6 P_{GH} + 0.0002 P_{GH}^2$ m³/s. Loss coefficient $B_{22} = 0.001 MW^{-1}$. Find the generation schedule, daily water used by the hydro plant and daily operating cost of the thermal plant for $r_j = 95.5$ Rs/m³-hr</p>	Analyze	3						
7	<p>A two plant hydro-thermal system with negligible losses has the following characteristics. Fuel cost as a function of active power generated at the thermal plant is $F = (2p_1 - 0.01p_1^2)$ RS/hr. The optimal water conversion co-efficient is found to be 12.01 RS/MCF. The load on the system is</p> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse; text-align: center;"> <tr> <td style="padding: 5px;">Duration (b)</td> <td style="padding: 5px;">9</td> <td style="padding: 5px;">15</td> </tr> <tr> <td style="padding: 5px;">DD (MW)</td> <td style="padding: 5px;">700</td> <td style="padding: 5px;">350</td> </tr> </table> <p>Compute the optimal active thermal and hydro power generations (in MW) in each of the subintervals and the allowable volume of water at the hydro plant.</p>	Duration (b)	9	15	DD (MW)	700	350	Analyze	3
Duration (b)	9	15							
DD (MW)	700	350							

8	A 3-phase single circuit, 220kV, line runs at no load. Voltage at the receiving end of the line is 205kV. Find the sending end voltage, if the line has resistance 21.7ohms, reactance of 85.2ohms and the total susceptance of 5.32×10^{-4} mho. The transmission line is to be represented by Pie-model.	Apply	3
9	A 3-phase single circuit, 220kV, line runs at no load. Voltage at the receiving end of the line is 215kV. Find the sending end voltage, if the line has resistance 25ohms, reactance of 100 ohms and the total susceptance of 5.32×10^{-6} mho. The transmission line is to be represented by Pie-model.	Apply	3
10	A 3-phase single circuit, 440kV, line runs at no load. Voltage at the receiving end of the line is 400kV. Find the sending end voltage, if the line has resistance 60 ohms, reactance of 150 ohms and the total susceptance of 5.72×10^{-4} mho. The transmission line is to be represented by Pie-model.	Analyze	3

UNIT-IV

Modeling of Turbines

1	Determine the primary ALFC loop parameters for a control area with the following data: Total generation capacity = 2500 MW Normal operating load =1500 MW Inertia constant=5 kW-seconds per kVA; Load damping constant, B=1 %; frequency, f=50 Hz; and Speed regulation, R=2.5 Hz / p.u MW.	Apply	3
2	A 100 MVA Synchronous generator operates at 50 Hz, runs at 3000 rpm under no- load. A load of 25 MW is suddenly applied to the machine. Due to the time lag in the governor system the turbine commences to open after 0.6 sec. Assuming inertia constant H= 5 MW- sec per MVA of generator capacity, calculate the frequency of the system before steam own commences to increase to meet the new load.	Apply	3
3	Two generating stations 1 and 2 have full load capacities of 200 MW and 100 MW respectively at a generating frequency of 50 Hz. The two stations are interconnected by an induction motor and synchronous generator with a full load capacity of 25 MW. The speed regulation of station 1, station 2 and induction motor and synchronous generator sets are 4 %, 3.5% and 2.5% respectively. The load on respective bus bars is 75 MW and 50 MW respectively. Find the load taken by the motor generator set.	Analyze	3
4	Two turbo alternators rated for 110 MW and 220 MW have governor drop characteristics of 5% from no load to full load. They are connected in parallel to share a load of 250 MW. Determine the load shared by each machine assuming free governor action.	Apply	3

5	Two generating stations 1 and 2 have full load capacities of 300 MW and 200 MW respectively at a generating frequency of 50 Hz. The two stations are interconnected by an induction motor and synchronous generator with a full load capacity of 50 MW. The speed regulation of station 1, station 2 and induction motor and synchronous generator sets are 45%, 4% and 3% respectively. The load on respective bus bars is 70 MW and 60 MW respectively. Find the load taken by the motor generator set.	Apply	3
6	Two turbo alternators rated for 150 MW and 250 MW have governor drop characteristics of 8% from no load to full load. They are connected in parallel to share a load of 300 MW. Determine the load shared by each machine assuming free governor action.	Analyze	3
7	Two generators rated 200MW and 400MW are operating in parallel. Draw the characteristics of their governors are 4% and 5% respectively from no load to full load. Assuming that the generators are operating at 50 Hz at no load, how would a load of 600MW be shared between them? What will be the system frequency at this load, Assume free governor operation, repeat the problem if both governors have drop of 4%.	Analyze	3
8	Two generators rated 400MW and 700MW are operating in parallel. Draw the characteristics of their governors are 6% and 8% respectively from no load to full load. Assuming that the generators are operating at 50 Hz at no load, how would a load of 900MW be shared between them? What will be the system frequency at this load, Assume free governor operation, repeat the problem if both governors have drop of 7%.	Analyze	3
9	Determine the primary ALFC loop parameters for a control area with the following data: Total generation capacity = 3500 MW Normal operating load =2500 MW Inertia constant=25 kW-seconds per kVA; Load damping constant, B=2 %; frequency, f=50 Hz; and Speed regulation, R=3.5 Hz / p.u MW	Apply	3
10	A 400 MVA Synchronous generator operates at 50 Hz, runs at 3000 rpm under no- load. A load of 50 MW is suddenly applied to the machine. Due to the time lag in the governor system the turbine commences to open after 0.6 sec. Assuming inertia constant H= 9 MW- sec per MVA of generator capacity, calculate the frequency of the system before steam own commences to increase to meet the new load.	Apply	3
<p>UNIT-V</p> <p>Single Area Load Frequency Control</p>			
1	A 125 MVA turbo alternator operates on full load at 50 Hz. A load of 50MW is suddenly reduced on the machine. The steam valves to the turbine commence to close after 0.5 seconds due to the time lag in the governor system. Assuming inertia constant H= 6 kW - sec per kVA of generator	Apply	4

	capacity, calculate the change in frequency that occurs in this time.											
2	<p>The single area control system has the following data: $T_P=10$ sec, $T_g = 0.3$ sec, $T_t=0.2$ sec, $K_P =200$ Hz/pu MW, $R=6$ Hz/pu MW, $P_D=0.5$ pu MW, $K_i=0.5$. Compute the time error caused by a step disturbance of magnitude 0.5 pu (as given above). Prove, in particular, that the error is reduced by increasing the given K_i. Express the error in seconds and cycles if the system frequency is 50 Hz.</p>	Analyze	4									
3	<p>A single area consists of two generators with the following parameters: Generator 1 = 1200 MVA; $R=6\%$ (on machine base) Generator 2 = 1000 MVA; $R=4\%$ (on machine base) The units are sharing 1800 MW at normal frequency 50 Hz. Unit 1 supplies 1000 MW and unit 2 supplies 800 MW. The load now increased by 200 MW.</p> <p>(a) Find steady state frequency and generation of each unit if $B=0$.</p> <p>(b) Find steady state frequency and generation of each unit if $B=1.5$.</p>	Analyze	4									
4	<p>A single area consists of two generating units with the following</p> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="padding: 5px;">unit</th> <th style="padding: 5px;">Rating in MVA</th> <th style="padding: 5px;">Speed regulation R (p.u on unit MVA base)</th> </tr> </thead> <tbody> <tr> <td style="padding: 5px;">1</td> <td style="padding: 5px;">600</td> <td style="padding: 5px;">6%</td> </tr> <tr> <td style="padding: 5px;">2</td> <td style="padding: 5px;">500</td> <td style="padding: 5px;">4%</td> </tr> </tbody> </table> <p>characteristics. The units are operating in parallel, sharing 900 MW at a nominal frequency. Unit 1 supplies 500 MW and unit 2 supplies 400 MW at 60 Hz. The load is increased by 90 MW.</p> <p>(a) Assume there is no frequency dependent load i.e., $B=0$. Find the steady state frequency deviation and new generation on each unit.</p> <p>(b) The load varies 1.5 % for every 1 % change in frequency i.e., $B= 1.5$. Find the steady state frequency deviation and new generation on each unit.</p>	unit	Rating in MVA	Speed regulation R (p.u on unit MVA base)	1	600	6%	2	500	4%	Apply	4
unit	Rating in MVA	Speed regulation R (p.u on unit MVA base)										
1	600	6%										
2	500	4%										
5	<p>A Generator in single area load frequency control has the following parameters: Total generation capacity = 2500 MW Normal operating load =1500 MW Inertia constant=5 kW-seconds per kVA; Load damping constant, $B=1\%$; fre- quency, $f=50$ Hz; and Speed regulation, $R=2.5$ Hz / p.u MW. If there is a 1.5 % increase in the load, find the frequency drop</p> <p>(a) without governor control</p> <p>(b) With governor control.</p>	Analyze	4									
	A250MVA synchronous generator is operating at 1500 rpm, 50 Hz. A load of 50 MW is suddenly applied to the machine and the station valve to the		4									

6	turbine opens only after 0.5 sec due to the time lag in the generator action. Calculate the frequency at which the generated voltage drops before the steam flow commences to increase to meet the new load. Given that the valve of H of the generator is 3.5 KW-s per KVA of the generator energy.	Apply	
7	Two Generating Stations A And B have full load capacities of 250 and 100MW, respectively. The interconnector connecting the two stations has an induction motor/synchronous generator of full load capacity 30 MW; percentage changes of speeds of A, B and C are 4, 3 and 2 respectively. Determine the load taken by plant C and indicate the direction of the power flow.	Analyze	4
8	A 750 MW generator has a speed regulation of 3.5%. If the frequency drops by 0.1Hz with an Unchanged reference, determine the increase in turbine power. And also find by how much the reference power setting should be changed if the turbine power remains unchanged	Analyze	4
9	A500MVA synchronous generator is operating at 1500 rpm, 50 Hz. A load of 100 MW is suddenly applied to the machine and the station valve to the turbine opens only after 0.5 sec due to the time lag in the generator action. Calculate the frequency at which the generated voltage drops before the steam flow commences to increase to meet the new load. Given that the valve of H of the generator is 5 KW-s per KVA of the generator energy.	Apply	4
10	Two Generating Stations A And B have full load capacities of 350 and 500MW, respectively. The interconnector connecting the two stations has an induction motor/synchronous generator of full load capacity 40 MW; percentage changes of speeds of A, B and C are 5, 4 and 2 respectively. Determine the load taken by plant C and indicate the direction of the power flow	Apply	4
<p>UNIT-VI</p> <p>Two-Area Load Frequency Control</p>			
1	Two areas A and D are interconnected. The generating capacity of area A is 36000 MW and its regulating characteristic is 1.5% of capacity per 0.1 Hz. Area D has a generating capacity of 400 MW and its regulating characteristic is 1% of capacity per 0.1 Hz. Find each area's share of a +400 MW disturbance (increase in load) occurring in area D and the resulting tie- line flow.	Apply	4
2	Find the static frequency drop if the load is suddenly increased by 25 MW on a system having the following data: Rated capacity $P_r=500\text{MW}$; operating load $P_D=250\text{MW}$ Inertia constant $H=5\text{s}$; Governor regulation $R=2\text{ Hz p.u.MW}$ Frequency $f= 50\text{ Hz}$. Also find the additional generation.	Analyze	4
3	Two areas of a power system network are interconnected by a tie-line, whose capacity is 250MW, operating at a power angle of 45°. If each area has a capacity of 2000 MW and the equal speed regulation of 3 Hz/P.u MW,		4

	determine the frequency oscillation on the power for step change in load. Assume that both areas have the same inertia constants of $H = 5$ sec. If a step load change of 100MW occurs in one of the areas determine the change in tie-line power.	Analyze	
4	Two power systems, A and B, having capacities of 3000 and 2000 MW, respectively, are interconnected through a tie-line and both operate with frequency-bias-tie-line control. The frequency bias for each area is 3 % of the system capacity per 0.1 Hz frequency deviation. If the tie-line interchange for A is set at 100 MW and for B is set (incorrectly) at 200 MW, calculate the steady state change in frequency.	Apply	4
5	Two control areas have the following characteristics: Area-1: Speed regulation = 0.2 p.u ,Damping coefficient = 0.8 p.u ,Rated MVA = 1500 Area-2: Speed regulation = 0.25 p.u, Damping co-efficient = 0.9 p.u, Rated MVA = 500 Determine the steady state frequency change and the changed frequency following a load change of 120MW occurs in area-1. Also find the tie-line power flow change.	Apply	4
6	The two area system has the following data: Capacity of area 1, $P_{r1} = 1000$ MW, Capacity of area 2, $P_{r2} = 2000$ MW, Nominal load of area 1, $P_{D1} = 500$ MW Nominal load of area 1, $P_{D1} = 1500$ MW Speed regulation of area 1 = 4% Speed regulation of area 2 = 3% Find the new steady state frequency and change in the line ow for a load change of area 2 by 125 MW. For both the areas each percent change in frequency causes 1 percent change in load. Find also the amount of additional frequency drop if the interconnection is lost due to certain reasons.	Analyze	4
7	Explain the state variable model of two area load frequency controller with integral action. Two control areas connected by a tie line have the following characteristics. Area 1 Area 2	Analyze	4

	<p>R=0.01 p.u R=0.02 p.u</p> <p>D=0.8 p.u D=1.0 p.u</p> <p>Base MVA=2000 Base MVA=500</p> <p>A load change of 100 MW (0.2 p.u) occurs in area 1. What is the new steady state frequency and what is the change in the tie own? Assume both areas were at nominal frequency (60 Hz) to begin.</p>		
8	<p>Two generators rated 250 MW and 500 MW are operating in parallel. The droop characteristics are 4% and 6% respectively. Assuming that the generators are operating at 50 HZ at no load, how a load of 750 MW would be shared. What is the system frequency? Assume free governor action</p>	Apply	4
9	<p>Two control areas have the following characteristics:</p> <p>Area-1: Speed regulation = 0.04 p.u ,Damping coefficient = 0.6 p.u ,Rated MVA = 1300</p> <p>Area-2: Speed regulation = 0.03 p.u, Damping co-efficient = 0.85 p.u, Rated MVA = 500</p> <p>Determine the steady state frequency change and the changed frequency following a load change of 150MW occurs in area-1. Also find the tie-line power flow change.</p>	Apply	4
10	<p>Two areas of a power system network are interconnected by a tie-line, whose capacity is 350MW, operating at a power angle of 450. If each area has a capacity of 3000 MW and the equal speed regulation of 6Hz/P.u MW, determine the frequency of oscillation of the power for step change in load. Assume that both areas have the same inertia constants of H = 5 sec. If a step load change of 120MW occurs in one of the areas determine the change in tie-line power.</p>	Apply	4
<p>UNIT-VII</p> <p>Load Frequency Controllers</p>			
1	<p>A 210 MVA, 50 Hz Turbo Alternator operates at no load at 3000 rpm. A load of 75 MW is suddenly applied to the machine and the steam valves to the turbine commence to open after 1 sec due to the time lag in the governor system. Assuming Inertia Constant H of 5Kw-sec per kVA of generator capacity. Calculate the frequency to which the generated voltage drops before the steam flow commences to increase to meet the new load.</p>	Apply	4
2	<p>The data pertaining to a single area power system with linear load-frequency characteristics are as follows:</p> <p>Rated Capacity = 2000 MW System Load = 1000 MW</p> <p>Inertia Constant = 5 sec Speed regulation = 0.03 pu</p> <p>Load damping factor = 1 pu Nominal Frequency = 50 Hz</p>	Analyze	4

	<p>Governor Time constant = 0 sec Turbine time constant = 0 sec For a sudden change in load of 20 MW, determine the steady state frequency deviation and the change in generation in MW and reduction in original load in MW</p>		
3	<p>The data pertaining to a single area power system with linear load-frequency characteristics are as follows: Rated Capacity = 1200 MW System Load = 600 MW Inertia Constant = 4 sec Speed regulation = 4% Load damping factor = 0.85 pu Nominal Frequency = 50 Hz Governor Time constant = 0 sec Turbine time constant = 0 sec For a sudden change in load of 40 MW, determine the steady state frequency deviation</p>	Analyze	4
4	<p>A two area power system has two identical areas with parameters are given below: Rated Capacity of the area = 3000 MW Nominal Operating load = 1500 MW Inertia Constant = 4 sec Speed regulation = 4% Load damping factor = 1 pu Nominal Frequency = 50 Hz Governor Time constant = 0.06 sec Turbine time constant = 0.3 sec A load increase $M_2 = 30$ MW, occurs in area 2 Determine i) the steady state frequency deviation ii) ΔP_{12s}</p>	Analyze	4
5	<p>The single area control system has the following data: $T_P = 10$ sec, $T_g = 0.3$ sec, $T_t = 0.2$ sec, $K_P = 200$ Hz/p.u MW, $R = 6$ Hz/p.u MW, $P_D = 0.5$ p.u MW, $K_i = 0.5$. Compute the time error caused by a step disturbance of magnitude 0.5 p.u (as given above). Prove, in particular, that the error is reduced by increasing the given K_i. Express the error in seconds and cycles if the system frequency is 50 Hz.</p>	Apply	4
6	<p>Determine the frequency of oscillations of the tie-line power deviation for a two identical area system given the following data: $R = 3.0$ Hz/p.u ; $H = 5$ s ; $f^0 = 60$ Hz The tie-line has a capacity of 0.1 p.u and is operating at a power angle of 45°.</p>	Apply	4
7	<p>Two interconnected Area-1 and Area-2 have the capacity of 2000 and 500 MW, respectively. The incremental regulation and damping torque coefficient for each area on its own base are 0.2 p.u and 0.8 p.u respectively. Find the steady state change in system frequency from a nominal frequency of 50 Hz and the change in steady state tie-line power following a 750 MW change in the load of Area-1</p>	Apply	4
8	<p>Solve the above problem without governor control action.</p>	Apply	4
9	<p>Find the nature of dynamic response if the two areas of the above problem are of uncontrolled type, following a disturbance in either area in the form of a step change in electric load. The inertia constant of the system is given as $H = 3$s and assume that the tie line has a capacity of 0.09 p.u and is operating</p>	Analyze	4

	at a power angle of 30° before the step change in load.		
10	<p>Two control areas have the following characteristics</p> <p>Area-1: Speed regulation=0.02 p.u Damping coefficient=0.8 p.u Rated MVA = 1500</p> <p>Area-2: Speed regulation =0.025 p.u Damping coefficient = 0.9 p.u Rated MVA = 500</p> <p>Determine the steady state frequency change and the changed frequency following a load change of 120 MW, which occurs in Area-1. Also find the tie-line power flow change.</p>	Analyze	4

UNIT-VIII
Reactive Power control

1	<p>Briefly explain the different methods of reactive power injection in the power system. 10 In a radial transmission system shown in figure, all p.u values are referred to the voltage bases shown and 100 MVA. Determine the power factor at which the generator must operate.</p>	Apply	5
2	<p>Find the rating of synchronous compensator connected to the tertiary winding of a 132 kV star connected, 33 kV star connected, 11 kV delta connected three winding transformer to supply a load of 66 MW at 0.8 p.f. lagging at 33 kV across the secondary. The equivalent primary and secondary winding reactances are 32 ohms and 0.16 ohms respectively while the secondary winding reactance is negligible. Assume that the primary side voltage is essentially constant at 132 kV and maximum of nominal setting between transformer primary and secondary is 1.1.</p>	Analyze	5
3	<p>A 3-phase single circuit, 220kV, line runs at no load. Voltage at the receiving end of the line is 205kV. Find the sending end voltage, if the line has resistance of 21.7ohms, reactance of 85.2ohms and the total susceptance of 5.32×10^{-4} mho. The transmission line is to be represented by Pie-model.</p>	Apply	5
4	<p>Design a static VAR compensator for a low voltage distribution system with the following specifications:</p> <p>System voltage = 440 V</p>	Apply	5

	<p>System frequency = 50 Hz</p> <p>Coil inductance, $L=5.37$ mH</p> <p>The inductor saturates at 950 A and settles to a value of 1.8 mH at 1800 A. Compensation is required over a range of -80 kVAR to +30 kVAR per phase.</p>		
5	<p>The load at receiving end of a three-phase, over head line is 25.5 MW, power factor 0.8 lagging, at a line voltage of 33 kV. A synchronous compensator is situated at receiving end and the voltage at both the ends of the line is maintained at 33 kV. Calculate the MVAR of the compensator. The line has a resistance of 4.5 ohms per phase and inductive reactance (line to neutral) of 20 ohms per phase.</p>	Analyze	5
6	<p>A 3-ph transmission line has resistance and inductive reactance of 25 and 90 respectively. With no load at the receiving end a synchronous compensator there takes a current lagging by 900, the voltage at the sending end is 145 kV and 132 kV at the receiving end. Calculate the value of the current taken by the compensator. When the load at the receiving end is 50 MW, it is found that the line can operate with unchanged voltages at sending and receiving ends, provided that the compensator takes the same current as before but now leading by 900. Calculate the reactive power of the load.</p>	Analyze	5
7	<p>A 440V, 3-\emptyset distribution feeder has a load of 100 KW at lagging p.f. with the load current of 200A. If the p.f. is to be improved, determine the following:</p> <ul style="list-style-type: none"> i) Uncorrected p.f. and reactive load ii) New corrected p.f. after installing a shunt capacitor of 75 KVAR. 	Apply	5
8	<p>A synchronous motor having a power consumption of 50 KW is connected in parallel with a load of 200KW having a lagging p.f. of 0.8. If the combined load has a p.f. of 0.9, what is the value of leading reactive KVA supplied by the motor and at what p.f. is it working?</p>	Apply	5
9	<p>A 400V, 50Hz, 3-\emptyset supply delivers 200KW at 0.7 p.f. lagging. It is desired to bring the line p.f. to 0.9 by installing shunt capacitors. Calculate the capacitance if they are (a) Star connected and (b) Delta connected.</p>	Apply	5
10	<p>A 3-\emptyset, 500HP, 50Hz, 11KV star connected induction motor has a full load efficiency of 85% at lagging p.f. of 0.75 and is connected to a feeder. If the p.f. of load is desired to be corrected to 0.9 lagging, determine the following:</p> <ul style="list-style-type: none"> (a) Size of the capacitor bank in KVAR and (b) Capacitance of each unit if the capacitors are connected in delta as well as in star. 	Analyze	5